METER REQUEST APPLICATION
COMMERCIAL

WATER FIXTURE UNIT COUNTS

Are Fire Sprinklers required for this construction: Y/N

Total Water Fixture Unit Counts for this construction: _____

✓ Include: Water Meter Data Card – Public (for commercial projects)

North American Industry Classification Code (see listing on page 2): _____

A water meter shall be sized to ensure that the maximum demand (in gallons per minute) will not exceed 80% of the manufacturer's recommended maximum flow rate, as shown in Section 27.03. In no case shall the water meter size be less than ¾-inch.

Meter Rating:

Size	GPM
3/4"	24
1"	40
1-1/2"	80
2"	128
3"	400
4"	800
6"	1,600
8"	2,720
10″	4,000

OWNER INFORMATION		
Company Name:		
Contact Name:		Contact E-Mail Address:
Company Address:		
City:	State:	ZIP Code:
Phone:	Fax:	Cellular:

***Who is financially responsible for payment of the monthly water bill?**
(circle one) OWNER APPLICANT

APPLICANT INFORMATION		
Company Name:		
Contact Name:		Contact E-Mail Address:
Company Address:		
City:	State:	ZIP Code:
Phone:	Fax:	Cellular:

PROJECT INFORMATION		
Project Name:		Project Number:
Project Address:		
City:	State:	ZIP Code:
Lateral Size:	Meter Size:	Station No.:

Backflow Prevention Details are located at www.sdwas.com

Signature of Applicant:	Date: